


J.B. CONCRETE PRODUCTS, INC.

1500 GAL PUMP CHAMBER - 1 Piece - 1 Comp.

DATE:
Jan. 3, 2008

Drawing I.D.
PC_1500_TS



Notes:

1. CONFORMS TO ASTM C1227.
2. JOINT SEALED WITH BUTYL RUBBER SEALANT.
3. MINIMUM CONCRETE COMPRESSION STRENGTH 5,000 PSI AFTER 28 DAYS.
4. STATE APPROVED INLET AND OUTLET PIPE SEALS.

1 Arch St
PO Box 387
Putnam, CT 06260
(860)928-9365
F (860)928-9452
www.jbconcreteproducts.com